

To the almighty.

ॐ विश्वानाथ




## CERTIFICATE

It is certified that the work contained in the thesis titled **Islanding Detection And Power Quality Disturbance Detection And Classification in Active Distribution Network Using Signal Processing** by **Amit Kumar Thakur** has been carried out under my supervision and that this work has not been submitted elsewhere for a degree.

It is further certified that the student has fulfilled all the requirements of Comprehensive Examination, Candidacy and SOTA for the award of Ph.D. Degree.

Signature of Supervisor



24.12.2021

Professor S. P. Singh

Department. of Electrical Engineering

IIT(BHU), Varanasi

Varanasi – 221005



## DECLARATION BY THE CANDIDATE

I, **Amit Kumar Thakur**, certify that the work embodied in this thesis is my own bona-fide work and carried out by me under the supervision of **Prof. S. P. Singh** from July-2015 to December-2021, at the Department of Electrical Engineering, Indian Institute of Technology (BHU), Varanasi. The matter embodied in this thesis has not been submitted for the award of any other degree/diploma. I declare that I have faithfully acknowledged and given credits to the research workers wherever their works have been cited in my work in this thesis. I further declare that I have not wilfully copied any other's work, paragraphs, text, data, results, etc., reported in journals, books, magazines, reports dissertations, theses, etc., or available at websites and have not included them in this thesis and have not cited as my own work.

Date: 24.12.2021

Place: Varanasi

Amit Kumar Thakur  
Signature of the Student

(Amit Kumar Thakur)

## CERTIFICATE BY THE SUPERVISOR

It is certified that the above statement made by the student is correct to the best of my/our knowledge.

S. P. Singh  
24.12.2021

Professor S. P. Singh

Department. of Electrical Engineering

IIT(BHU), Varanasi

Signature of Head of Department/Coordinator of School

PROFESSOR & HEAD  
Department of Electrical Engineering  
Indian Institute of Technology (BHU)  
Varanasi, U.P. (INDIA)

Varanasi, U.P. (INDIA)



## COPYRIGHT TRANSFER CERTIFICATE

Title of the Thesis: **Islanding Detection And Power Quality Disturbance Detection  
And Classification In Active Distribution Network Using Signal Processing**

Name of the Student: **Amit Kumar Thakur**

### Copyright Transfer

The undersigned hereby assigns to the Institute of Technology (Banaras Hindu University), Varanasi all rights under copyright that may exist in and for the above thesis submitted for the award of the Doctor of Philosophy.

Date: 24.12.2021

Place: Varanasi

*Amit Kumar Thakur*  
(Amit Kumar Thakur)

**Note:** However, the author may reproduce or authorize others to reproduce material extracted verbatim from the thesis or derivative of the thesis for author's personal use provided that the source and the Institute's copyright notice are indicated.



## ACKNOWLEDGMENT

The conglomeration of inspiration, guidance, and support from many individuals has led to this work's successful completion. Therefore, I would like to take this opportunity here and acknowledge all those persons who have been instrumental and played a key role during my research.

First of all, I would like to express my deep sense of gratitude to my supervisor Prof. S.P. Singh, Department of Electrical Engineering, IIT (BHU) Varanasi, for his excellent support, skilled guidance, an abundance of patience, and constant encouragement during my research. I consider it my privilege to have the opportunity to work with him. I am especially expressing my sincere gratitude to my supervisor for providing the necessary support and constant encouragement during the entire period of my research work as Professor-in-Charge of the power system complex.

I would also like to thank the faculty members of my research progress evaluation committee, Prof. R. Mahanty, Department of Electrical Engineering, and Prof. L. P. Singh, Department of Mathematical Sciences, who have always provided me with the necessary support, guidance, criticism, and suggestions for necessary improvements in my thesis work. I also thank Dr. J.C. Pandey and Dr. S.R. Mohanty for their support during my endeavor of achieving high standards in work. The lab staff Mr. Sanjay Bharti has also been a kind and helping hand during the entire period.

Special gratitude goes out to my friends and colleagues, including Mr. Kartik Kumar, Mr. Ujjwal Kumar, Mr. Pratik Kumar, Dr. Satyendra P. Singh, Dr. Sunil Singh, Dr. Devesh Shukla, Dr. Shailendra Singh, Dr. Vijay Babu P., Mr. Shailendra Singh, Mr. Manohar Singh, and Mr. Akhilesh Barnwal.

I would like to express my deep sense of gratitude to my parents (Mr. Prabhash Thakur and Mrs. Ranjana Devi), my brother and sisters (Mr. Sumit, Mrs. Suman, Mrs. Sindhu and Mrs. Priti), my uncle (Mr. Shiv Mishra) and my brother-in-law and sister-in-law (Mr. Shashank and Ms. Shrishti) for their constant support and encouragement, without which this assignment would not have been completed at all. I am grateful to my other family members who have supported me along the way.

Last but not least, I take this opportunity to acknowledge the love, affection, support, and irreplaceable time strained by my wife, Mrs. Sakshi, that helped me in the successful completion of my thesis and my son Adyansh for always refreshing me with his toddling activities.

Date: - 24.12.2021

Place: Varanasi

Amit Kumar Thakur

(Amit Kumar Thakur)

# TABLE OF CONTENTS

CERTIFICATE.....	v
DECLARATION BY THE CANDIDATE.....	vii
COPYRIGHT TRANSFER CERTIFICATE .....	ix
Acknowledgment.....	xi
Table of Contents.....	xiii
List of Figures.....	xvii
List of Tables .....	xxiii
List of Abbreviations and Symbols.....	xxv
Preface .....	xxvii
Chapter 1 Introduction and Literature Review.....	33
1.1 background overview .....	33
1.2 Motivation and problem statement .....	36
1.2.1 Issues of High penetration RE .....	37
1.3 Literature survey.....	38
1.3.1 Islanding detection in Active Distribution Network.....	38
1.3.2 Power Quality Disturbance classification and detection .....	45
1.4 Research gap and motivation .....	49
1.5 Thesis Organization.....	50
1.6 Summary.....	50
Chapter 2 Application of Signal processing methods in Islanding and power quality disturbance detection.....	51
2.1 Introduction .....	51
2.2 Signal processing methods .....	51
2.2.1 Fourier Transform .....	53
2.2.2 Short-Time Fourier Transform .....	53
2.2.3 Wavelet Transform .....	54
2.2.4 Empirical Mode Decomposition .....	55
2.3 Recent signal processing methods .....	56
2.4 Variational mode decomposition .....	57
2.5 Summary.....	59
Chapter 3 PASSIVE METHOD FOR ISLANDING DETECTION USING VARIATIONAL MODE DECOMPOSITION .....	61
3.1 Introduction .....	61
3.2 VMD: overview .....	62

3.2.1	VMD: algorithm .....	64
3.2.2	Selection of VMD parameter .....	65
3.3	Implementation of the proposed VMD-based IDT .....	66
3.4	Simulation results and discussions .....	68
3.4.1	Test system I: five-bus system .....	70
3.4.2	Non-islanding event .....	71
3.4.3	Islanding event .....	73
3.4.4	ET selection .....	73
3.4.5	Capacitor switching event .....	76
3.4.6	Simultaneous capacitor switching and islanding events .....	76
3.4.7	Load-switching events .....	78
3.4.8	Simultaneous load rejection and islanding events .....	78
3.4.9	Fault events .....	79
3.4.10	Assessment of performance of the proposed method on other kinds of load and operating conditions .....	81
3.4.11	Test system II: practical distribution system .....	84
3.5	Summary .....	86
Chapter 4 Real-time simulation of variational mode decomposition method for islanding detection		87
4.1	Introduction .....	87
4.2	proposed islanding detection technique description .....	88
4.2.1	Modal Voltage Signal .....	89
4.2.2	VMD .....	90
4.2.3	Selection of Mode for energy calculation .....	91
4.2.4	Mode Energy (ME) index calculation .....	91
4.2.5	Computational Burden .....	92
4.3	Simulation results and discussion .....	92
4.3.1	Test system I: .....	93
4.3.2	VMD based modal voltage decomposition under various test conditions .....	94
4.3.3	Threshold selection .....	96
4.3.4	Non-islanding event .....	98
4.3.5	Islanding event .....	104
4.3.6	Analysis of NDZ for proposed IDT .....	107
4.3.7	Test system II: .....	109
4.4	Comparative assessment of the proposed IDT with existing methods .....	111
4.5	Validation in real-time using real-time digital simulator (RTDS) Platform .....	113

4.5.1	Non-Islanding cases .....	115
4.5.2	Islanding Situations .....	115
4.6	Summary .....	117
Chapter 5	Detection and classification of power quality disturbance using variational mode decomposition .....	119
5.1	mathematical modeling Power quality disturbances .....	119
5.1.1	Sag .....	120
5.1.2	Swell .....	120
5.1.3	Interruption .....	121
5.1.4	Harmonic Distortion .....	122
5.1.5	Flicker .....	122
5.2	Classification methodology .....	123
5.2.1	VMD .....	124
5.2.2	Power quality disturbance(PQD) index .....	125
5.3	Implementation of proposed vmd based pqd estimator .....	126
5.4	Result and discussion .....	128
5.4.1	Test System .....	128
5.4.2	Voltage sag, swell, and interruption .....	132
5.4.3	Harmonic .....	132
5.4.4	Flicker .....	134
5.5	Validation of proposed vmd based method on practical recorded data .....	135
5.5.1	Result and Discussion .....	136
5.6	Real-Time validation for Microgrid test system on real time digital simulator .....	138
5.6.1	Result and discussion .....	141
5.7	Summary .....	144
Chapter 6	Conclusion and Future Scope .....	145
6.1	Conclusion .....	145
6.2	Future Scope .....	148
References	.....	149
A.	Appendix: .....	159
B.	Publication .....	161
	Publication in referred and peer-reviewed Journals .....	161
	Publication in national/international conferences .....	163



## LIST OF FIGURES

Figure 1.1 Renewable electricity generation, World [1] .....	34
Figure 1.2 Renewable electricity generation, India [1] .....	34
Figure 1.3 Phase of system Integration of renewables [2] .....	35
Figure 1.4 RE generation growth and Electricity demand Increment in India [1] .....	36
Figure 1.5 Block Diagram of representation of EPS .....	38
Figure 1.6 Classification of Islanding Detection Technique .....	39
Figure 1.7 Classification of Remote/communication-based IDT .....	40
Figure 1.8 classification of active IDT .....	41
Figure 1.9 Classification of Passive IDT methods .....	44
Figure 1.10 Classification of PQ disturbances .....	45
Figure 2.1 Signal Processing Methods .....	52
Figure 3.1 Basic block of VMD .....	63
Figure 3.2 Flow diagram of VMD.....	66
Figure 3.3 Off-line Simulation Platform .....	69
Figure 3.4 Flow chart of the proposed scheme for islanding detection.....	69
Figure 3.5 Modified five-bus test system .....	70
Figure 3.6 Decomposed voltage signals into IMFs .....	71
Figure 3.7 Energy plot of IMF2 under normal condition .....	72
Figure 3.8Decomposed voltage signal into IMF during islanding .....	72

Figure 3.9 Energy of IMF2 during islanding ..... 72

Figure 3.10 Decomposed voltage signal during capacitor switching event ..... 77

Figure 3.11 Energy of IMF2 during capacitor switching ..... 77

Figure 3.12 Energy of IMF2 during subsequent capacitor switching and ..... 77

Figure 3.13 Energy of IMF2 during a load switching event ..... 78

Figure 3.14 Energy plot of IMF2 (a) 33% of total load rejection, (b) 66% of total load rejection ..... 79

Figure 3.15 Performance of the proposed IDT during fault inception of bus 5 (a) Target DG end voltage during LG fault, (b) Energy of IMF2 during LG fault, (c) Target DG end voltage during LLG fault, (d) Energy of IMF2 during LLG fault ..... 80

Figure 3.16 Performance of the proposed IDT during fault inception of bus 5 (a) Target DG end voltage during LL fault, (b) Energy of IMF2 during LL fault, (c) Target DG end voltage during LLLG fault, (d) Energy of IMF2 during LLLG fault ..... 81

Figure 3.17 Performance of the proposed IDT during switching of an induction machine (a) Voltage signal of DG end, (b) Energy of IMF2 of decomposed signal ..... 82

Figure 3.18 Performance of the proposed IDT under various critical mismatch conditions (a) Zero power, (b) APM, (c) RPM ..... 83

Figure 3.19 Single line diagram of a practical distribution network ..... 84

Figure 3.20 Energy of IMF2 during islanding under zero power mismatch ..... 85

Figure 3.21 Energy of IMF2 for LG, LLG, LL, and three-phase (LLL) faults in practical distribution system ..... 86

Figure 4.1 Flow chart of Proposed Scheme for Islanding Detection ..... 89

Figure 4.2 Single line diagram of Test system I.....	93
Figure 4.3 Non-islanding event (a) modal voltage (b) Decomposed signals .....	95
Figure 4.4 Capacitor switching case (a) modal voltage (b) decomposed signal .....	95
Figure 4.5 Islanding case (a) modal voltage (b) decomposed signal.....	96
Figure 4.6 Mode energy of various simulated events for threshold selection in (a) Test system 1 (b) Test system II.....	97
Figure 4.7 The energy of mode2 during (a) capacitor (b) subsequent load switching (c) Reactor switching .....	99
Figure 4.8 The mode energy of signal for various fault conditions (a) fault at bus2 (b) fault at PCC .....	101
Figure 4.9 The mode energy of signal (a) HIF (b) LIF .....	102
Figure 4.10 The mode energy of signal during Sag and Swell events .....	102
Figure 4.11 The mode energy of signal during noise disturbances SNR ratio (20,30,35,40 and 45 db) .....	103
Figure 4.12 Performance of purposed IDT during IM starting (a) modal voltage (b) energy of mode2 .....	104
Figure 4.13 The mode energy plot in (a) zero power mismatch (b) active power mismatch (c) reactive power mismatch.....	106
Figure 4.14 Mode energy plot for different types of DG in case of Islanding .....	107
Figure 4.15 Comparision of NDZ of the proposed IDT with conventional relays (over voltage /frequency and under voltage/frequency) .....	108

Figure 4.16 One-line diagram of Test system-II [102] .....	109
Figure 4.17 The energy of mode2 for Test system II (a) LLLG (b) different non-islanding events, (c) Islanding conditions at different power mismatch conditions .....	111
Figure 4.18 Real-time simulation platform for the implementation of the proposed IDT (a) Block diagram (b) Laboratory setup .....	114
Figure 4.19 Performance of the purposed IDT in RTDS platform (a) subsequent capacitor banks on and off (b) different types of faults events (c) Islanding event (d) Islanding and capacitor switching simultaneously.....	117
Figure 5.1 Power Quality disturbances (a) Sag (b) Swell (c) Interruption (d) Harmonics .....	121
Figure 5.2 Offline simulation setup for implementing proposed VMD based PQD detection .....	124
Figure 5.3 Flow chart of VMD based classification of Power quality disturbances....	127
Figure 5.4 One-line diagram of the Test system .....	128
Figure 5.5 Power quality disturbance in case of Sag (a) Voltage and Decomposed IMFs (b) RMS index for classification of Sag (c) Standard deviation .....	129
Figure 5.6 Power quality disturbance in case of Swell (a) Voltage and Decomposed IMFs (b) RMS index for classification of Swell (c) Standard deviation .....	130
Figure 5.7 Power quality disturbance in case of Interruption (a) Voltage and Decomposed IMFs (b) RMS index for classification of PQ disturbance (c) Standard deviation .....	131
Figure 5.8 Power quality disturbance in case of Harmonics (a) Voltage and Decomposed IMFs (b) RMS index for classification of PQ disturbance (c) Standard deviation .....	133

Figure 5.9 Power quality disturbance in case of Harmonics (a) THD (b) Estimated center frequency .....	133
Figure 5.10 Power quality disturbance in case of Flicker (a) Voltage and Decomposed IMFs (b) RMS index for classification of PQ disturbance (c) Standard deviation .....	135
Figure 5.11 Power quality disturbance in case of Flicker (a) THD (b) Estimated center frequency .....	135
Figure 5.12 PQD disturbance in Almunium sheet Facility (a) sag, (b) swell. ....	137
Figure 5.13 Arc furnace Facility in case of interruption and harmonic (a) RMS (b) THDv .....	137
Figure 5.14 Substation 1 mixed types of PQD (a) RMS(IMF1) (b) THDv.....	138
Figure 5.15 Real-Time Co-simulation Platform.....	139
Figure 5.16 Draft Microgrid model in RSCAD.....	140
Figure 5.17 Run time Microgrid model.....	140
Figure 5.18 Real-time Generation and categorization (a) Voltage sag(b) Voltage swell .....	141
Figure 5.19 Voltage waveform decomposition by VMD in case of swell and harmonics .....	142
Figure 5.20 PQD index (a) Instantaneous RMS (b) THDv .....	143



## LIST OF TABLES

Table 1-1 Differences in Active and Passive IDTs .....	45
Table 2-1 General comparison of Signal Processing Method .....	58
Table 2-2 Comparison in Time frequency decomposition technique.....	59
Table 3-1 Steps of signal decomposition.....	63
Table 3-2 Implementation of VMD based IDT algorithm .....	67
Table 3-3 Maximum energy for various cases of test system I.....	75
Table 3-4 Maximum energy for various cases of test system II.....	75
Table 3-5 Types of events .....	85
Table 4-1 Comparison of Computational Burden .....	92
Table 4-2 Considered simulated test cases .....	94
Table 4-3 The mode energy of various critical cases of test systems.....	98
Table 4-4 Comparison of recent IDT with the proposed method.....	113
Table 5-1 PQD mathematical model .....	122
Table 5-2 Threshold value for PQD indices.....	126
Table 5-3 Threshold value for Harmonic and flicker PQD index .....	127
Table 5-4 Dataset generated for testing .....	128
Table 5-5 Harmonic data taken from IEEE task force data base [113].....	136
Table 0-1 Thevenin equivalent grid, PVDG, and Transformer data .....	159
Table 0-2 Generator parameters .....	159

Table 0-3 Publication from thesis' work..... 161

Table 0-4 Publication from work done other than the thesis. .... 162

Table 0-5 Publication in national/international conferences. .... 163

## LIST OF ABBREVIATIONS AND SYMBOLS

DG	Distributed Generation
DER	Distributed Energy Resources
IDT	Islanding Detection Technique
VMD	Variational Mode Decomposition
EMD	Empirical mode Decomposition
EWT	Empirical Wavelet Transform
IMF/Mode	Intrinsic Mode Function
RER	Renewable energy resources
MG	Micro-grid
WDG	Wind based DG
PVDG	Photovoltaic based DG
SDG	Synchronous based DG
ADN	Active distribution network.
SP	Signal Processing
GTNET	Giga-Transceiver Network Communication Card.
SKT	Socket Protocol
GTSYNC	Synchronization Card.
RTDS	Real Time Digital Simulator.
GTAO	Giga-Transceiver analog output
GTAI	Giga-Transceiver analog input
RSCAD	Real-Time Simulation Computer aided design
PSCAD	Power System Computer aided design
DFIG	Doubly fed induction generator

PMSM	Permanent magnet synchronous machine
LG	Line to ground fault
LLG	Line-Line to ground fault
LL	Line to Line fault
LLLG	Triple Line to ground fault(symmetrical fault)
PQD	Power Quality Disturbance
$\omega_m$	Central frequency
$\alpha$	Reconstruction fidelity factor
$\mathcal{L}$	Augmented Lagrangian
$\lambda$	Lagrangian multiplier

## PREFACE

The great emphasis and environmental concern have globally driven Renewable Energy (RE) integration into the power grid. The penetration of RE at the lower level to the grid does not pose any challenge. However, the RE integration at the higher level may pose additional challenges to grid operation because of the intermittency and variability of RE. Moreover, the inclusion of renewable sources poses additional significant challenges such as bidirectional power flow in the network that may cause malfunctioning of the relays, relay coordination, voltage/frequency control, and islanding detection issues.

The present work exploits the signal processing-based advanced approach for ascertaining, classification, and depicting abnormal events in Active Distribution Networks (ADN). Islanding is a phenomenon when a portion of ADN is isolated from the rest of the power network due to disturbances/faults or intentional isolation in the power grid. The Power Quality Disturbances (PQD) such as sag, swell, and interruption are also caused by abnormal events and faults in the system. The load demand is increasing day by day in the electric grid, and to meet the increased power demand, more emphasis is given to renewable energy resources due to the faster depletion of fossil fuel and environmental concerns associated with it. Ascertaining unintentional islanding conditions is challenging for power utility operators due to the pervasive penetration of Distributed Energy Resources (DER). The presence of DER has a significant adverse impact on islanding detection schemes for various types of Distributed Generators (DG) and inverter-based DERs. Before integrating DG into ADN, the issue of unintentional islanding detection has been desirable to be deliberated.

The conventional islanding protection method such as Vector Surge (VS) and Rate of Change of Frequency (ROCOF) relays has usually been used to detect islanding,

but its performance is limited by the large Non-Detection Zone (NDZ), wherein islanding events are undetected by these conventional relays. For VS and ROCOF relays, NDZ is a function of active and reactive power deficit, which may exist inside the islanded segment. This thesis's proposed approaches are developed based on multiple features of three-phase voltage signals that can be recorded in ADN through Potential Transformers (PTs). However, the voltage selection over the current signal is advantageous because these voltage and current signals are passed through the instrument transformers, i.e., Potential Transformer (PT) and Current Transformer (CT). The voltage and current, which come out from the instrument transformers, are inputs to the abnormal events detection devices, such as relays or other intelligent devices. Therefore, the reliability of PT and CT is an essential aspect for the detection devices to detect abnormalities effectively. CT suffers from issues like magnetic saturation and non-linearity, especially during fault or abnormal conditions. In contrast, PT/CCVTs provide excellent reproduction of primary voltage during both transient and steady-state. Some CCVTs may exhibit a subsidence transient when the system voltage is suddenly reduced, such that the secondary voltage is not the replica of the primary voltage. Modern design CCVTs are available to eliminate this problem. Usually, PT does not experience saturation since power systems are not operated above the voltage limit, and in most cases, faults result in a collapse or reduction in voltage, or sometimes voltage may rise, but it does not cause saturation. Therefore, classification and characterization of abnormal events utilizing only voltage parameters would undoubtedly provide an accurate insight into the events. Hence, voltage and its associated features have been taken as input parameters for the proposed method.

This thesis proposes a Variational Mode Decomposition (VMD)-based approach for detecting and classifying islanding events in an ADN. The prime attributes of VMD

are noise immunity, robustness, and non-recursive signal processing approaches, making it more promising and competent for signal decomposition than other extant signal processing methods. The energy-based index has been assigned for islanding detection. In this thesis, using the concept of NDZ, the performance of the Islanding Detection Technique (IDT) has been evaluated for islanding detection. The limitations of the VS and ROCOF relays for islanding detection, in case of a minor power mismatch between load and generation, exist in the islanded network. From the perspective of the problems and the limitations of the conventional methods, this thesis proposes VMD based technique for islanding detection of synchronous, Doubly Fed Induction Generator (DFIG), and inverter type DG. The proposed method addresses a passive islanding detection mechanism based on mode energy index using VMD in ADN. In this, three-phase instantaneous voltages at the targeted DG end have been acquired to compute modal voltage signals, and VMD has been applied to decompose the obtained signals into four modes. Thereupon, the mode energy index has been calculated for the selected mode. The estimated energy index has ultimately been utilized as an islanding detection indicator. Two different test systems have been modeled in this work simulated on EMTDC/PSCAD using test system data. Furthermore, all possible combinations of mismatch of active and reactive power, which may exist during the occurrence of an island, have been considered in the testing. A comparative study between conventional relays (VS and ROCOF) and the proposed VMD-based IDT has been conducted, and the proposed method's relative performance has been evaluated. The simulation outcome reasserted that the developed approach effectively ascertains the islanding and non-islanding events.

Furthermore, the proposed islanding detection technique has been validated using the Real-Time Digital Simulator (RTDS). The simulator consists of NovaCor chassis with

four licensed cores and RSCAD 5.013 versions. The simulation is performed in Power system mode, having a solution time step of 50 microseconds. NovaCor chassis has 12×12 bit digital to analog channels (GTAO) operating over a range of ±10 V peak. The PCC three-phase voltage has been sent from the front panel interface of RTDS (GTAO) to MicroLabBox (dSPACE1202) ADC pin, where the proposed algorithm has been implemented. The modal voltage has been decomposed, and the energy of the second mode is computed. The computed energy is compared with the threshold value. If it is greater than the predefined threshold, a trip signal is generated and sent to RTDS by the GTNET-SKT communication protocol.

The work is further extended for the assessments of Power Quality Disturbances (PQD) as they pose a significant challenge due to the increased usage of electronic equipments since all these equipment are susceptible to voltage and frequency variations. These devices are highly sophisticated, and their performance depends on the quality of the power supply. Voltage sag is generally considered a power-quality problem of equal importance as long and short interruptions in the supply. It has become very challenging to control the external factors that cause voltage dips. Thus, proper mitigation techniques are desired. However, the development of mitigation techniques requires the accurate diagnosis, characterization, and classification of voltage sag. Furthermore, the classification of voltage sag and swells plays a vital role in assessing voltage sag ride-through capability and immunity of electrical equipment. This thesis proposes a signal processing-based classifier to detect and classify PQD effectively. The VMD-based signal processing has been used to extract the decomposed mode. The decomposed modes carrying the signature of disturbances are segregated. The sag, swell, and interruption are disturbances that depend on the Root Mean Squared (RMS) of the voltage signal. One of the decomposed modes has been utilized to classify the disturbances, which depends on

RMS. Frequency-dependent disturbances are classified by THD of the mode and center frequency estimated by VMD. A mathematical model for PQD assessment has been developed in the MATLAB environment, and various types of disturbances, i.e., voltage sag, swell, interruption, and THD, are obtained. The proposed technique is tested with the dataset obtained from the models simulated in PSCAD/EMTDC platform. Furthermore, actual measurement data provided by the IEEE Task Force database is utilized to test the technique's efficacy. Moreover, a real-time co-simulation platform has been developed to validate the proposed PQD detection method using RTDS/RSCAD and MATLAB.